



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 18/01/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	S ON CO 19 B/C LEFT	OLR ACTED	RESET	00:00:00	00:15:00	
2	OHP	S ON CO 19 LUFF LEFT	MPCB TRIPPED DUE TO CABLE EARTH FAULT	PROPERLY INSULATED	03:00:00	03:20:00	
3	OHP	CO 19	CONTROL MCB ONE POLE GOT MELTED AND DAMAGED	TO BE CHECKED	05:45:00	06:00:00	
4	CHP	SCR 5 ON CC 32 B/C	OLR ACTED	RESET	03:50:00 05:05:00 22:50:00	04:00:00 05:15:00 23:00:00	
5	CHP	SCR 1 ON CC 34	SLEW DRIVE TRIPPED	RESET	02:00:00	02:15:00	
6	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	02:40:00	04:00:00	4 TIMES
7	CHP	CC 131	OLR ACTED	RESET	03:40:00 04:45:00	03:45:00 04:50:00	
8	CHP	CC 29	OLR ACTED	RESET	01:40:00 23:05:00	01:45:00 23:10:00	
9	CHP	CC 14	CONTROL MCB TRIP	MADE IT ON	04:20:00 05:30:00	04:35:00 05:40:00	