



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 04/07/2025

Shift: C

Incharge(s): Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 35A , CO 37A	BRS to be bypassed as per operation request due to belt holes	BRS bypass done at CJB	22:25:00	22:40:00	
2	OHP	RSCO 6A	OLR acted	reset done	03:30:00	03:40:00	
3	OHP	CO 26	OLR acted	reset done	00:05:00 23:18:00	00:15:00 23:27:00	
4	OHP	TBS on CO 20	Left boom luffing not working	OLR acted, reset done. Also found that limit arrested by rope , released .	00:30:00	00:45:00	
5	OHP	BRC on CO 31	BC not running due to OLR acted	OLR reset done	00:00:00	00:20:00	
6	OHP	CO 35	OLR acted	reset done	02:45:00 03:25:00	02:50:00 03:30:00	
7	OHP	CO 63	MPCB tripped	made on	03:50:00	04:00:00	
8	CHP	CC 36 , S-1	LT not working	Stop PB got stuck, made free . Then LT healthy and working	22:50:00	23:10:00	
9	CHP	CC 36 , S-1	LT not working	PCRD overtension acted , released	00:50:00	01:05:00	
10	CHP	CC 32, SCR 5	Slew not working	Due to 30 degree limit acted , informed operation and released	01:10:00	01:20:00	
11	CHP	CC 125	Tripped on overload	reset done	04:38:00	04:45:00	
12	CHP	CC 33	Tripped on overload	reset done	04:50:00	05:10:00	
13	CHP	CC 117	MCCB tripped	Checked, found that motor burned . Motor replaced , trial run taken and given clearance to operation	23:15:00	05:25:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 04/07/2025

Incharge(s): Arnab Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC 52	OLR acted	reset done	05:00:00	05:10:00	