



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 14/08/2025

Shift: C

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 35	OLR acted	reset done	01:40:00 03:35:00	01:45:00 03:40:00	
2	OHP	CO 111	Em PB acted	checked, malfunctioning . So bypassed Em PB contact bypassed	22:15:00	22:30:00	
3	OHP	CO 26	OLR acted	reset done	00:15:00	00:35:00	
4	CHP	CC 33 , SCR 4	LT end limit to bypass as per opn request	bypassed	22:30:00	22:45:00	
5	CHP	CC 38 , SCR 6	BC signal missing	LT done	00:00:00	00:30:00	
6	CHP	CC 36 , S 2	LT not working	OT acted , released	01:00:00	01:20:00	
7	CHP	CC 201	Tripped on overload	reset done	02:05:00	02:20:00	
8	CHP	CC 36 , S 2	Slew not working	slew area coal jamming , informed to operation	02:20:00	02:30:00	
9	CHP	CC 34 , SCR 2	Luff Up not working	oil level low, informed to mechanical	02:40:00	03:00:00	
10	CHP	CC 104 , SCR 9	BC frequently stopped	checked, wrong complaint . chute jamming , informed to operation	04:40:00	05:10:00	
11	CHP	CC 29	ZSS acting frequently bcz deck sheet touching zss cage	informed to mechanical and operation	00:20:00	00:30:00	
12	CHP	CO 26	OLR acted	reset done	00:25:00	00:35:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 14/08/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC 51	MPD tripped many times . Overload acted 4 times	reset done . Return side jamming , deck sheet problem , informed to operation	22:30:00	05:30:00	before overload reset , motor checked . Temp found normal
14	CHP	CC 38	BRS to be bypassed as per operation request	bypass done	02:48:00	02:51:00	in system
15	WT	OP 1	Not moving	D 6 overload acted , reset done	00:50:00	01:00:00	