



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 19/02/2026

Area: OHP

Equipment	Job
co-5a	electrical brs is removed, mechanical brs installed and taken in circuit.
brc-1 on co-8a	ppm is done
CR-3A vibration sensor	fixed back and checked.
tt-1 pcrd cable	cable insulation is done properly and winding done.