



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 16/11/2025

Incharge(s): Lal Singh,Lal Singh

Shift: A

| Sl No | Area | Equipment      | Problem                    | Action                     | From                             | To                               | Remarks |
|-------|------|----------------|----------------------------|----------------------------|----------------------------------|----------------------------------|---------|
| 1     | OHP  | CO-26          | TRIPPED ON OLR             | RESET DONE                 | 09:20:00<br>13:20:00             | 09:30:00<br>13:30:00             |         |
| 2     | OHP  | CO-32 BRC      | LT NOT WORKING             | PCRD OT ACTED ... RELEASED | 07:30:00                         | 07:45:00                         |         |
| 3     | CHP  | CC-47          | ZSS PROBLEM                | PROB CABLE FIXED PROPERLY  | 08:30:00                         | 08:45:00                         |         |
| 4     | CHP  | CC-125         | TRIPPED ON OLR             | RESET DONE                 | 10:00:00                         | 10:10:00                         |         |
| 5     | CHP  | CC-45          | TRIPPED ON OLR             | RESET DONE                 | 10:40:00<br>11:05:00<br>11:50:00 | 10:45:00<br>11:10:00<br>11:55:00 |         |
| 6     | CHP  | CC-34<br>SCR-1 | SLEW 30 DEGREE LIMIT ACTED | RELEASED                   | 12:30:00                         | 12:40:00                         |         |
| 7     | CHP  | CC-26          | FLAP GATE MPCB TRIPPED     | MADE ON                    | 09:10:00                         | 09:20:00                         |         |
| 8     | CHP  | CC-54          | TRIPPED (8 TIMES )         | RESET DONE                 | 07:10:00                         | 13:30:00                         |         |