



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 21/11/2025

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO 5A LT	M1, M2 OLR ACTED	RESET	18:35:00	18:45:00	
2	OHP	CO 85	OLR ACTED	RESET	19:20:00	20:20:00	3 TIMES
3	OHP	TBS ON CO 7A RIGHT LUFF UP	LIMIT TIED	REMOVED THEN OK	19:45:00	20:00:00	
4	OHP	CO 25	OLR ACTED	RESET	19:45:00	19:55:00	
5	OHP	BRC ON CO 30	B/C OLR ACTED DUE TO JAMMING	RESET	20:40:00	20:50:00	
6	OHP	TT4 F/G	OLR ACTED	RESET	18:00:00	18:10:00	
7	OHP	RSCO 6A CD	OLR ACTED	RESET	14:05:00	14:15:00	
8	CHP	CC 51	FEEDING CON OLR ACTED	RESET	16:30:00	20:30:00	
9	CHP	CC 51	OLR ACTED	RESET	16:30:00 20:20:00	16:35:00 20:25:00	
10	CHP	CC 52	FEEDING CONVEYOR OLR ACTED	RESET	17:30:00 18:50:00	17:35:00 18:55:00	2 TIMES
11	CHP	CC 54	OLR ACTED	RESET	20:25:00 21:05:00	20:30:00 21:10:00	
12	CHP	CO 26	OLR ACTED	RESET	17:40:00	17:50:00	
13	CHP	CC 47	DRIVE TRIPPED	RESET	18:30:00	18:40:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 21/11/2025

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	SCR 6 ON CC 38 LT	DRIVE FAULT	RESET	19:55:00	20:10:00	
15	WT	OC 1A	OLR ACTED	RESET	16:30:00	16:40:00	
16	WT	OT3	DRIVE 1 TRIPPED ON ENCODER FAULT	RESET	16:00:00	16:10:00	
17	WT	CO 3	OLR ACTED DUE TO JAMMING	RESET	21:00:00	21:10:00	
18	IOSA	OC 7B	ZSS CAGE STUCK WITH COAL PIECE	REMOVED THEN OK	20:45:00	21:05:00	