



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/01/2026

Incharge(s): Amit Roy

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|-----------------------------|---|----------|----------|---------|
| 1 | OHP | CO-21 | Yard ZSS problem | Probe check nut loose.Tightened and tested okay | 14:00:00 | 14:11:00 | |
| 2 | OHP | TBS on CO-19 | Right luff not working | Wrong complaint | 14:50:00 | 15:00:00 | |
| 3 | OHP | CO-84 | Reported tripped | OLR acted.Reset done | 16:11:00 | 16:15:00 | |
| 4 | OHP | BRC on CO-30 | B/C not running | Yard ZSS module wire loose. Tightened and tested okay | 18:00:00 | 18:40:00 | |
| 5 | OHP | TBS on CO-22 | chute sensor malfunctioning | Kept in Bypass | 19:45:00 | 20:00:00 | |
| 6 | CHP | Cc-28 | Reported tripped | OLR acted.Reset done | 17:30:00 | 17:40:00 | |
| 7 | CHP | CC-51 | MPD acted | Reset done(8 times) | 15:10:00 | 21:30:00 | |
| 8 | CHP | CC-51 | Tripped | OLR acted.Reset done | 17:50:00 | 17:55:00 | |
| 9 | CHP | CC-219 | ZSS acting | Cage stuck.Cage replaced | 18:15:00 | 18:35:00 | |
| 10 | CHP | CC-213 | B/C not working | Material selection not given by CPP.Bypassed in program | 19:00:00 | 19:30:00 | |
| 11 | CHP | CC-108 | Reported tripped | OLR acted.Reset done | 20:55:00 | 21:00:00 | |
| 12 | CHP | CC-213 | Chute sensor acting | Acting due to moisture.Bypassed at module. | 20:45:00 | 20:55:00 | |
| 13 | WT | OP-8 | Communication problem | Module power recycled | 14:00:00 | 14:10:00 | |
| 14 | WT | OP-2 | Reported tripped | D1,D5 tripped.Reset done | 14:30:00 | 14:45:00 | |
| 15 | WT | Af-2A | E-stop PB not releasing | Wrong complaint | 15:00:00 | 15:10:00 | |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/01/2026

Incharge(s): Amit Roy

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------|---------------------|--|----------|----------|---------|
| 16 | WT | OP-4 | Reported not moving | Top pad fallen. Welding done and pad kept in place and tested okay | 19:30:00 | 21:00:00 | |