



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 10/02/2026

Shift: C

Incharge(s): Amit Roy

| Sl No | Area | Equipment     | Problem                        | Action   | From     | To       | Remarks  |
|-------|------|---------------|--------------------------------|--|----------|----------|--|
| 1     | OHP  | CO-8          | Reported BRS not healthy       | Checked and found BRS reset button stuck up.Made free and both BRS checked and kept in line. | 23:30:00 | 23:45:00 | P/C bypassed at MCC panel as per operation request |
| 2     | OHP  | CO-5A         | Reported BRS acting frequently | Checked and found BRS to be okay but found belt offcentered in between around 40 metres      | 23:40:00 | 00:00:00 |  |
| 3     | OHP  | CO-26         | Reported tripped               | OLR acted.Reset done   | 00:25:00 | 00:35:00 |  |
| 4     | OHP  | CO-36         | Tripped                        | OLR acted.Reset done   | 01:00:00 | 01:10:00 |  |
| 5     | OHP  | WOBR on CO-29 | Reported B/W not rotating      | Checked and found motor burnt.   | 02:45:00 | 04:00:00 | Motor to be replaced                               |
| 6     | OHP  | WOBR on CO-25 | LT not taking place            | Drive tripped.Reset done   | 04:00:00 | 04:15:00 |  |
| 7     | OHP  | CO-36         | Reported tripped               | OLR acted.Reset done   | 01:10:00 | 01:15:00 |  |
| 8     | CHP  | CC-51         | MPD tripped                    | Reset done   | 00:50:00 | 00:55:00 |  |
| 9     | CHP  | CC-54         | Reported tripped               | OLR acted.Reset done   | 01:20:00 | 01:25:00 |  |
| 10    | CHP  | CC 104 SCR-7  | LT not taking place            | Drive tripped.Reset done   | 23:30:00 | 23:38:00 |  |
| 11    | CHP  | CC-104 SCR-7  | BC not running                 | TUL chute jamming found.   | 23:40:00 | 23:45:00 |  |



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 10/02/2026

Incharge(s): Amit Roy

Shift: C

| Sl No | Area | Equipment        | Problem                             | Action   | From     | To       | Remarks                            |
|-------|------|------------------|-------------------------------------|--|----------|----------|------------------------------------|
| 12    | CHP  | CC 105<br>SCR-10 | Reported no operations taking place | Checked and found one fuse blown at I/O.Coupler opened and found machine side one core problem | 03:10:00 | 05:50:00 | Informed to general shift incharge |
| 13    | CHP  | CC-213           | Reported tripped                    | OLR acted.Reset done   | 04:30:00 | 04:40:00 |                                    |
| 14    | CHP  | CC 108           | Reported tripped                    | OLR acted.Reset done   | 05:20:00 | 05:25:00 |                                    |