



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 15/05/2025

Area: OHP

Equipment	Job
tt-1 on co-21	position sensor and plug, terminations were checked and kept in circuit
tt-3	chute position plugs were checked and tightness is ensured.
co-16	motor side ppm is done
tis on co-25	on feedback circuit is checked, temporarily bypassed CSR contact.
rsco-6a belt	control circuit is checked and tested in remote mode.
co-11a gallery	new ldb box is welded in position