



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/07/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RSCO 10A(B)	olr acted	reset	09:30:00	09:40:00	
2	OHP	CO 35	olr acted	reset	10:00:00	10:10:00	
3	OHP	TBS on CO 22	LT not taking place, OT acted	OT released	11:30:00	11:45:00	
4	OHP	WOBR on CO 25	LT not taking place, M4 olr acted	reset	12:00:00	12:15:00	
5	OHP	LC7	I/C 2 tripped in LBDS 1-1LBDS 4, in 50 G	fault reset ,i/c made on in LBDS	11:00:00	11:30:00	
6	CHP	CC 104 SCR 9	B/w not running, in lower house PLC EB03 fault	lower house to upper house plc communication established by changing port of OFC in unisol ,than boom conveyor control ckt checked, than B/W control ckt checked found EStop acted, Estop released than ok after that all interlocked checked found all ok	07:40:00	09:40:00	
7	CHP	CC 32 SCR 5	LT not taking place, MPCB 2 trips	made it on	07:00:00	07:10:00	
8	CHP	CC 57	stopping in ZSS fault, zss probe wire got cut	cable jointed	06:35:00	06:55:00	
9	CHP	CC 51 A	olr acted 2 times	reset	09:20:00	09:25:00	
10	CHP	CC 58	trips in CURT SP fault	reset	12:25:00	12:40:00	
11	CHP	CC 40 SCR 4	LT not working, M2 mpcb trips	made it on	08:20:00	08:30:00	
12	CHP	CC 34 SCR 2	LT not taking place, OT acted	OT released	09:40:00	09:50:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/07/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC 38 SCR 3	B/C not running, zss fault	module side TB tightened than zss healthy	12:40:00	12:50:00	
14	WT	OP2	fwd not moving from parking zone, Parking zone timer problem	parking zone timer replaced	08:50:00	09:00:00	
15	IOSA	OLD WOBR	LT not taking place, OT acted	OT released	13:15:00	13:30:00	