



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 24/06/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO 20	LT NOT TAKING PLACE PCRD O/T ACTED	RELEASED	01:00:00	01:15:00	
2	OHP	WOBR ON CO 25	B/C NOT RUNNING ZS PROBE DAMAGED	PROBE REPLACED THAN OK	01:00:00	01:20:00	
3	OHP	CO 11 BELT DRIVE	OLR ACTED	RESET	04:22:00	04:30:00	
4	CHP	CC 31 R1	b/c and b/w not running, bucket is jammed with material	informed operation for cleaning, than ok	23:45:00	23:55:00	
5	CHP	CC 203	motor not healthy,, motor tripped in overload	MPD reset	01:20:00	01:30:00	
6	CHP	CC 105 scr10	b/c not running, signal missing in micrologix plc	ethernet cable removed and plugin than ok	02:05:00	03:20:00	
7	CHP	CC 39 SCR 7	slew not working, spider alarm (brake failed)	spider reset	04:20:00	04:30:00	
8	CHP	CC131	OLR ACTED	RESET	00:20:00	05:35:00	
9	CHP	CC 33	yard conveyor motor olr acted	reset MPR	04:55:00	05:05:00	
10	CHP	CC 34 scr2	LT not taking place, OT acted	OT released	05:20:00	05:30:00	
11	CHP	CC 32 SCR5	LT not taking place, MPCB 1,2,3 tripped due to wheel 4	mpcb made on, informed operation	22:40:00	23:00:00	
12	WT	op 7	no power, acb tripped bottom insulator punctured @ colno 87	packing provided, ACB made on	01:35:00	02:10:00	
13	WT	SCO 1A(C)	OLR ACTED	RESET	02:55:00	03:00:00	