



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 16/07/2025

Area: IOSA

Equipment	Job
OC-13A , OC-14A	PPM DONE ON MOTORS.
OC-13A	ONE PULLCHORD SWITCH SHOWING OPERATED AND NOT GETTING HEALTHY. CONTACT NOT MAKING PROPERLY. RECIFIED SAME.
BRC AND WONR (FLS)	HYDRAULIC POWER PACK XMD PANEL MAINTENANCE DONE.
OC-19A	BRS UNITS MAINTENANCE AND FEEDBACK CHECKING DONE.
BRC	BRAKE PANELS MADE READY AND CHECKING DONE AND SHIFTED TWO PANEL TO BRC CT PLATFORM FOR HARROWS EM BRAKES.
OC-18A	PPM DONE ON FIELD DEVICES.
OC-9A, OC-11A	BRS AND ZSS INSPECTION and FEEDBACK CHECKING DONE.