



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 30/09/2025

Area: WT

Equipment	Job
OT 1 Series	Running inspection done found normal
OP 5	checked @ parking zone,found bottom pad flush marking and jumpers loose, tightened
OP 2,3,4 and 6	After rake , maintenance done