



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 02/05/2025

Area: IOSA

Equipment	Job
BLENDER RECLAIMER	LT THRUSTER BRAKES CHECKING DONE AND DEFECTIVE LINER RECTIFICATION TAKEN UP.
OC-2A,5A,23A,27A	MOTOR PROTECTION RELAYS PARAMETERS AND CONNECTIONS CHECKED
TBS- PCRD	CABLE GOT UN-WINDED DUE TO CABLE GUIDE CHAIN PROBLEM. RECTIFIED AND RE-WINDED POWER CABLE
OC-4A	
UPS BATTERY	
UPS	