



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 23/10/2025

Area: IOSA

Equipment	Job
OC-15A	DAMAGED FIELD DEVICE CABLES RECTIFIED AND PULLCHORD SWITCHES RECTIFICATION AND FEEDBACK CHECKING IS IN PROGRESS.
TBS	BRAKE PANEL FOR EM BRAKES SHIFTED TO E-HOUSE AND WIRING DONE FROM LT VFD PANEL TO BRAKE PANEL. WORK IS IN PROGRESS
OC-29A	ELECTRICAL HOISTS AT HEAD END , NOT GETTING OPERATED FROM PENDENT. RECTIFIED AND CHECKED.
TBS	PPM DONE ON MOTORS AND PANEL SIDE OF RIGHT AND LEFT BOOM CONVEYOR.