



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 21/08/2025

Area: WT

Equipment	Job
OT 3 and 4	area lighting R-phase fuse base replaced in LC 1
OT 5 series	Running inspection done
CP 3	D2 burnt motor shifted to ore tippler complex, and coupling removed
OP 1	D6 cable R-phase got cut, made it joint, D4 slip ring buffing done and 2 nos brushes replaced
OP 1, 4 and 10	After rake maintenance done, top C-clamp replaced in OP 10