



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 16/12/2025

Incharge(s): G Eswara Rao

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 29	OLR ACTED	RESET DONE	17:10:00	17:20:00	
2	OHP	CO-31 BRC	BC NOT RUNNING ... EM PB ACTED	RELEASED	15:40:00	16:00:00	
3	OHP	CO 32 BRC	LT M4 OLR ACTED	RESET DONE	18:00:00	18:15:00	
4	CHP	CC-32 SCR-5	LUFF NOT WORKING	CHANGED STANDBY TO MAIN THEN TESTED INFORMED MECH FOR STAND BY PUMP CHECKING	15:15:00	16:00:00	
5	CHP	CC-35 SCR-3	BC NOT RUNNING	MPD TRIPPED ... RESET	19:00:00	19:10:00	
6	CHP	CC-34 SCR-1	LT NOT WORKING ... PCRD OT ACTED	RELEASED	20:50:00	21:00:00	
7	CHP	CC-51	MPD TRIPPED 9 TIMES	RESET DONE	16:50:00	21:40:00	
8	CHP	CC-54	OLR ACTED 10 TIMES	RESET DONE	19:30:00	21:35:00	
9	CHP	CM-15 CM-16	COMMUNICATION PROBLEM	WORK GOING ON	15:00:00	22:00:00	
10	CHP	CO-28 BRC	CT NOT WORKING	MCC SIDE CT LIMIT STRIKER DAMAGED	21:10:00	22:00:00	STRIKER TO BE WELDED
11	WT	CO-3	OLR ACTED	RESET DONE	15:30:00	15:40:00	