



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 16/08/2025

Area: IOSA

Equipment	Job
OC-13A	ZSS CAGE FIXTURE GOT DAMAGED.REPLACED WITH MODIFIED ZSS CAGE AND CHECKED FEEDBACK.
WOBR(L and T)	HYDRAULIC RAIL CLAMP ( LEFT) TRIPPING . FOUND MOTOR IR=0. REMOVED THE MOTOR AND SHIFTED TO ELECT SHED. LEFT RAIL CLAMP KEPT IN OPEN MANUALLY.
WOBR (FLS)	TESTED SPARE 5.5KW MOTOR SHIFTED FROM ELECTRICAL SHED TO MACHINE FOR REPLACING IN LT MOTOR-5 PLACE. AS MACHINE RUNNING REQUEST HAS CONE BROUGHT MOTOR TO MECH SHED.
OC-19A	ZSS CAGE FIXTURE GOT DAMAGED. REPLACED WITH MODIFIED ZSS CAGE AND FEEDBACK CHECKED.
OC-29A	LIGHTING DEFECTS RECTIFIED AND PROVIDED SUFFICIENT LIGHTING IN GALLERY
OC-37A	FOR RUNNING CONVEYOR IN REVERSE, PHASE REVERSAL DONE IN PJB. AFTER JOB NORMALIZED.
OC-23A	PPM DONE ON MOTOR
OC-21A	PPM DONE ON MOTOR