



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 27/05/2025

Area: CHP

Equipment	Job
CC112,32,33 BRS	BYPASS IN SYSTEM
coal complex	cleaning done
CC49 BRS	Checked found malfunction, plan for Tomorrow to fix mechanical BRS
CC38 SCR3	TUL chute sensor kept in ckt
CC111 BRS ,DE Chute sensor	kept in ckt
CC34-s1,CC35-SCR2	interchange machine shifting