



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 28/10/2025

Incharge(s): Amit Roy, K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-48	TRIPPED ON OLR	RESET DONE	22:10:00	22:30:00	
2	OHP	CO-51 (C)	TRIPPED ON OLR	RESET DONE	01:30:00	01:40:00	
3	OHP	CO-26	TRIPPED ON OLR (2TIMES)	RESET DONE	03:20:00 04:50:00	03:30:00 05:00:00	
4	OHP	CO-35	STOPPING ON ZSS CHECKED AND FOUND ZSS PROBE DAMAGED	ZSS PROBE REPLACED THAN OK	03:45:00	04:00:00	
5	OHP	CO-29	TRIPPED ON OLR	RESET DONE	05:45:00	05:55:00	
6	OHP	CO-58	TRIPPED ON OLR	RESET DONE	05:50:00	06:00:00	
7	OHP	TBS ON CO-5A	LT NOT TAKING PLACE CHECKED AND FOUND POWER MCCB AUX BLOCK PROBLEM	BYPASSED	00:40:00	01:00:00	
8	OHP	CO-28	REPORTED NOT HEALTHY PULL CHORD ACTED	PULL CHORD RESET THAN OK	02:40:00	02:50:00	
9	CHP	CC-54	TRIPPED ON OLR (6TIMES)	RESET DONE	23:55:00	02:00:00	
10	CHP	CC-114	OLR ACTED	RESET DONE	04:20:00	04:30:00	
11	CHP	CC-52	MPD TRIP	RESET DONE	05:05:00	05:10:00	
12	CHP	CC-105 SCR-10	B/C NOT RUNNING CHECKED AND FOUND MOTOR RUNNING BUT GARE BOX NOT RUNNING INFORMED TO MECHANICAL	FLUID COUPLING OIL REFILLED THAN OK	01:00:00	01:10:00	