



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 22/09/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 10	not healthy	power recycled	22:55:00	23:05:00	
2	CHP	CC 105 SCR 10	BC not running,olr acted	olr reset	23:15:00	23:35:00	
3	CHP	CC 104 SCR 9	slew not working.limit acted	limit released	23:15:00	23:40:00	
4	CHP	CC 38 SCR6	slew not working,jamming	informed operation	23:20:00	23:35:00	
5	CHP	CC 37 SCR 7	LT not working,LT power and control off due to LT wheel damaged condition	informed operation and mechanical	23:40:00	23:50:00	
6	CHP	CC 31 SCR 4	LT not working,OT acted	OT released	00:05:00	00:15:00	
7	CHP	CC 44	olr acted	reset	00:17:00	00:23:00	
8	CHP	CC 39 scr 3	signal missing complaint,	LT done than ok	03:52:00	04:00:00	
9	CHP	CC 34 SCR2	LT not working,OT limit acted	OT released	03:55:00	04:10:00	
10	CHP	CC 36 SCR1	LT not working,BW stucked in coal	luff up than ok	04:45:00	05:10:00	
11	CHP	CC 31 SCR4	LT not working,MPCB 5 tripped	made it on	05:20:00	05:30:00	
12	CHP	CC 51	MPD tripped	reset	04:00:00	04:10:00	
13	WT	OP4 and OP6	communication problem	ethernet cable unplugged plugged power recycled	03:35:00	03:55:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 22/09/2025

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	WT	CP3	communication	ethernet cable unplugged plugged power recycled	03:45:00	03:55:00	