



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 12/10/2025

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	DB-1	Reported tripped	OLR acted.Reset done	12:45:00	13:00:00	
2	OHP	CO-26	Reported tripped	OLR acted.Reset done	11:05:00	11:15:00	
3	OHP	TBS on CO-7A	Right luff tripping	brakes made loose and chute material jamming cleared after boom run and motor hot blowing done and up/down tested okay	08:20:00	09:30:00	
4	CHP	CC-33	Reported tripped	OLR acted(3 times) due to belt overload at T/E.Reset done	09:20:00	09:35:00	Tripped at 9.20,9.35,9.50
5	CHP	Cc-35 SCR-5	LT not working	Drive tripped.Reset done(2 times)	09:20:00 09:50:00	09:35:00 10:00:00	
6	CHP	CC-104 SCR-9	Slew and B/W not moving	Oil cooler motor trip and oil temperature high.Oil cooler made on and oil temperature found normal and tested okay	11:05:00	11:30:00	
7	WT	OC-1A	Reported Tripped	OLR acted(3 times).Reset done	12:00:00 12:40:00 13:10:00	12:05:00 12:50:00 13:20:00	
8	IOSA	OC-7B	Reported fail to start	Breaker racked out and inserted properly and tested okay	07:50:00	08:10:00	
9	IOSA	WOBR	LT not taking place	PCRD chain problem.Loop given for reclaiming	09:00:00	09:20:00	Informed to mechanical