



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 12/05/2025

Area: CHP

| Equipment | Job |
|-------------------|---|
| JH3 HOIST | GRAVITY LIMIT SWITCH REPLACED |
| CC 13, CC17, CC24 | PPM DONE |
| CCC 54 | MOTOR REPLACED AND ALIGNMENT DONE |
| SCR 8 | 6 NOS 35 LED FIXERS REPLACED, LUFF DOWN LIMIT STRIKER WELDED AND TESTED. UPS PANEL REMOVED. |
| R1 , S3, SCR8 | SHIFTED TO CC 31, CC111, CC112 RESPECTIVELY |