



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 11/10/2025

Area: WT

Equipment	Job
EOT COAL TIPPLER	FWD POWER CONTACTOR DAMAGE TWO TIPS CHANGE, R-PHASE LUGGING DONE
CO-3	CARRIAGE MOTOR TB FIXED PROPERLY
OP-1,4,6,8 CP-2,3,4	PUSHER INSPECTION DONE AT PARKING ZONE.