



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 11/08/2025

Area: WT

| Equipment | Job |
|--------------------|---|
| OT 1 and 2 Hoppers | Lighting improved, light fixers location re arranged ,3 nos 400 W fittings replaced |
| LC 9 | Lighting , circuit problem rectified and one tube installed @ GE I/O panel |
| OP 2 | After rake maintenance done |