



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 25/06/2025

Shift: A

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on CO 19	Light not working due to MCB tripped	MCB made on , lighting ok	06:40:00	07:00:00	
2	OHP	CO 76R	OLR acted	reset done	06:50:00	06:55:00	
3	OHP	TBS on CO 21	ZSS not working	Old joint loose connection , rejoined properly	10:00:00	10:20:00	
4	OHP	TBS on CO 22	Right luff not working	OLR acted , reset done	11:10:00	11:30:00	
5	OHP	CO 26	OLR acted	reset done	12:00:00	12:10:00	
6	OHP	CO 2A	BRS to be bypassed as per operation request	Bypassed at CJB	08:00:00	08:10:00	
7	OHP	CC 31	BRS to be bypassed	Bypassed	11:55:00	12:00:00	in system
8	CHP	CC 32 , SCR 5	LT not working	M-3 tripped , reset done	08:40:00	08:50:00	
9	CHP	CC 33	Drive end chute sensor acting	Bypassed in module	10:30:00	10:40:00	
10	CHP	CC 32	BRS ACTING	Bypassed in IO rack	10:30:00	10:40:00	
11	CHP	CC 39, SCR 7	BC not running due to chute sensor acting	Bypassed and again kept in circuit	13:30:00	14:00:00	
12	CHP	CC 53	TT not working due to OLR acted	reset done	08:40:00	08:50:00	
13	CHP	CC 131	Tripped on overload ( 4 times)	reset done	09:00:00	12:40:00	
14	CHP	RG 3	Flap gate motor tripped	reset done	09:50:00	09:55:00	
15	CHP	CC 54	Tripped on overload ( 3 times)	reset done	08:45:00	10:45:00	



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 25/06/2025

Shift: A

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
16	WT	OP 10	Not healthy	D-4 and D-6 bypassed in system . Refer to Gen shift	12:45:00	13:15:00	
17	IOSA	OC 7B	Chute sensor to be bypass as per operation request	Bypassed	11:15:00	11:30:00	again kept in circuit at 2 pm