



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 27/08/2025

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 87	not healthy stops in ZSS,zss cage bearing jammed	zss cage replaced	17:00:00	17:30:00	
2	OHP	WOBR on CO 25	no supply,acb tripped	made it on	18:00:00	18:20:00	
3	OHP	WOBR on CO 25	b/c not running,ZSS cage stucked with stone	cage made free	18:15:00	18:30:00	
4	OHP	CO 3A	not healthy, pull chord acted left rear,NC contact probelm	NC contact bypass	16:30:00	16:45:00	
5	OHP	CO 76 R two way chute	not working,olr module burn	module replaced with spare	17:20:00	17:35:00	
6	OHP	TT4	no movement,mpcb trips	made it on	18:30:00	18:45:00	
7	OHP	TT 4	not healthy,CS acted	reset	19:00:00	19:10:00	
8	CHP	scr10 on cc 105	b/c not running, mpd trips	reset	15:35:00	15:45:00	
9	CHP	CC 32 SCR 5	LT not taking place,m6 mpcb trips	made it on	16:30:00	16:40:00	
10	CHP	CC 40 SCR 3	b/ not running,all ok	fault reset done in operator cabin than ok	19:05:00	19:10:00	
11	CHP	CC 32 SCR 5	b/c not running,olr acted	reset	19:30:00	19:40:00	
12	CHP	CC 113	stopped in ZSS due to material overload	informed operation	18:50:00	20:00:00	3 times



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 27/08/2025

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC 52	BRS not healthy, cleaning both transmitter and receiver	than ok	14:30:00	15:00:00	
14	CHP	CC 54	olr acted	reset	20:05:00	20:10:00	2 times
15	CHP	CC 114	OLR acted	reset it done	20:45:00	20:55:00	
16	CHP	CC 44	olr acted	reset	21:45:00	21:55:00	
17	WT	OP 10	no movement, mccb trips ,D-3 i/c to drive cable flash	d3 bypass in scada	16:30:00	17:10:00	
18	IOSA	OC 7C	not running, conveyor healthy, power contactor problem, tips melted	power contactor replaced from spare feeder	21:45:00	22:30:00	refer to c shift