



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/09/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	brc on co-31	LT NOT WORKING .. OT ACTED	RELEASED	00:10:00	00:30:00	
2	OHP	BRC ON CO -31	BC NOT RUNNING .. OLR ACTED	RESET DONE	02:55:00	03:15:00	
3	CHP	CC-131	TRIPPED ON OLR	RESET DONE	01:45:00 04:45:00	01:50:00 04:50:00	
4	CHP	CC-54	TRIPPED ON OLR (4 TIMES)	RESET DONE	23:40:00	05:10:00	
5	CHP	CC-51	MPD TRIPPED	RESET DONE	03:55:00 23:50:00	04:00:00 23:55:00	
6	CHP	CC 40 , SCR 3	Signal missing	LT done	22:30:00	22:45:00	
7	CHP	CC 36 , SCR 1	Luff not working	Checked, found electrical side okay. Found oil level low , informed mechanical	23:00:00	23:30:00	
8	CHP	CC 39 , SCR 7	BC signal missing frequently	LT done , PLC recycled , antena cleaning	00:15:00	01:00:00	
9	CHP	CC 32, SCR 5	LT not working	Drive tripped, reset done	00:30:00	00:45:00	
10	WT	CC-3	TRIPPED ON OLR (4 TIMES DUE TO JAMMING)	RESET DONE	02:15:00	05:50:00	