



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/07/2025

Shift: B

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR ACTED(2TIMES)	RESET	14:15:00	14:30:00	
2	OHP	WOBR ON CO 6A	INTERLOCK CAGE STUCK UP	ZS CAGE FREE IT THAN OK	15:00:00	15:15:00	
3	OHP	BRC ON CO 33M	HYDRALIC PUMP NOT STARTING	WRONG COMPLAINT	15:15:00	15:30:00	
4	OHP	WOBR ON CO 6A	INTERLOCK ZS CAGE STUCK UP	ZS CAGE REPLACED WITH NEW ONE THAN OK	16:00:00	16:20:00	
5	OHP	VS-1A	Reported Tripping without load	Checked and found DMPR acting on PH fault. CT and DMPR changed and tested okay	17:15:00	19:15:00	
6	OHP	BRC-4 on CO-34	Reported B/W-2 tripping on ZSS	BW-2 ZSS bypass done at I/O rack	19:15:00	20:00:00	BW-1,2 ZSS both are in byapss. to be checked and to be rectified
7	OHP	TBS on CO-20	Left boom stopping on zss	Probe damaged. replaced and tested okay	19:30:00	19:45:00	
8	OHP	TBS on CO-23	LT not taking place	M2,M4 OLR acted.Reset done and tested okay	21:15:00	21:30:00	
9	OHP	CO-29	Reported Red	OLR acted.Reset done	17:30:00	17:40:00	
10	CHP	CC-26 FG	Reported not moving	OLR acted.Reset done	14:00:00	14:10:00	
11	CHP	CC 105 SCR 7	LT not taking place	Pending problem.Mechanical problem rectified and trial run taken	14:40:00	15:50:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/07/2025

Incharge(s): Amit Roy,K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	CC-40 S-1	Signal missing	LT forward done and tested okay	15:55:00	16:10:00	
13	CHP	CC-34 SCR-2	LT not taking place	PCRD OT acted. tension released and tested okay	16:10:00	16:20:00	
14	CHP	CC-34,35	Reported red	Tripped on earth fault in LBDS. Charged and tested okay	16:20:00	16:30:00	
15	CHP	CC-33 SCR-4	Reported LT not taking place	M2 tripped. Motor isolated	17:20:00	17:50:00	to be checked and to be kept in line
16	CHP	CC-104 SCR 9	B/C stopping frequently	Signal problem. LT done and tested okay	20:10:00	20:20:00	
17	WT	OP3	Not moving	Rotor contact stuck up(5A1). released and tested okay	14:30:00	15:15:00	
18	WT	CO-3	Reported Red	OLR acted(2Times)	18:50:00	19:05:00	
19	IOSA	OC-25A	Reported red	OLR acted.reset done	14:00:00	14:30:00	