



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/12/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	wobr on co 25	slew not working,olr acted	reset	00:00:00	00:20:00	
2	OHP	TBS on co 22	LT not running,M1 OLR acted	reset	03:45:00	04:00:00	
3	OHP	CO 11A	fdr ready for operation not healthy,pullchord acted	pullchord bypasssed in panel xy13to xy-14	22:35:00	23:35:00	
4	CHP	CC 112 scr8	cabin adjustment disturbed	adjusted	22:25:00	22:40:00	
5	CHP	CC 31 scr4	Lt not working,pcrd OT acted	OT released	23:00:00	23:09:00	
6	CHP	CC 39 scr6	LT not working,drive tripped	reset	05:00:00	05:15:00	
7	CHP	CC 51	mpd tripped due to overload 25 times	reset	23:30:00	06:00:00	
8	CHP	CC 52	mpd tripped on Ol	reset	01:00:00	04:30:00	
9	CHP	CC 117	tripped in olr	reset	02:00:00	05:35:00	4 times
10	CHP	CC 131	motor tripped in olr 2 times	reset	03:30:00	05:30:00	