



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/05/2025

Incharge(s): K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR ACTED	RESET	01:00:00 22:30:00	01:10:00 22:40:00	
2	OHP	BRC ON CO 33M	B/C NOT RUNNING E/STOP ACTED	RELEASED	00:00:00	00:15:00	
3	CHP	CC 39	ZS PROBLEM CHECKED BELT OFF CENTRING	IN FORMED TO MECH	05:00:00	05:15:00	
4	CHP	CC 35 SCR 2	LT NOT TAKING PLACE O/T ACTED	OT released	01:00:00	01:20:00	
5	CHP	CC 38 SCR 3	LT not taking place, drive trips in overload	reset it done	00:14:00	00:40:00	
6	CHP	CC 38 SCR 3	luffing down not working,full jamming in limit switch area	informed operation	00:30:00	00:40:00	
7	WT	OP 10	no fwd movement , OT 2 LS2 fb not came	clamp de clamp done than ok	23:30:00	23:35:00	