



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 22/10/2025

Area: OHP

| Equipment | Job |
|-----------------------------|--|
| co-2a | 2 switches replaced and taken pull-chords in circuit. |
| tt-4 | ppm is done. |
| fb-5 and fb-6 bunker levels | scaling is done and indications provided in ocr hmi. |
| tbs- on co-7a | both luff drive are checked ,found fault at dbr end, proper termination done and tested. |
| co-31a,32a gallery | illumination inspection is done. |
| dewatering | 1-141lc3,1-141lc4, om-24,jho-14 de-watering is done. |
| co-27a,30a,32a | safety devices ppm is done |
| LOSP-2 | motor and panel side ppm is done. |
| co-9a motor | base bolts tightness checked and tightened. |