



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 05/05/2025

Area: IOSA

Equipment	Job
OC-19A	
UPS	CABLE ( 16 SQMM , 4 CORE) BROUGHT FROM MANUAL CRUSHING YARD ( 2B) TO LC-2. CABLE LAYED BETWEEN OM-5, 6 AND BATTERY BANK TO UPS PANEL.

UPS & BATTERY CHARGER