



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 20/02/2026

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-67	Reported tripped	OLR acted.Reset done	22:15:00	22:25:00	
2	OHP	BRC on CO-28	No operations taking place	ACB tripped.Reset done	02:00:00	02:15:00	
3	OHP	BRC on CO-30	Reported CT not moving	CT wheel derailed	02:30:00	02:45:00	Informed to mechanical
4	OHP	CR-1	Reported tripped	Motor protection relay tripped on overcurrent.Reset done and found no movement in motor.Motor decoupled and made to run but no movement found.Checked and found one fuse opened at MCC panel.Motor and cable meggered and found okay.Fuse replaced from CR-2 panel and found no abnormalities.Motor made to run and tested okay	01:00:00	04:30:00	
5	CHP	Cc-213	Reported not healthy	Drive tripped.Reset done	22:30:00	22:45:00	
6	CHP	Cc-40 SCR-2	B/C not running	OLR acted.Reset done	23:20:00	23:30:00	
7	CHP	CC-31 SCR-4	B/W not running	B/W stuck in material.LT reverse done and tested okay	00:20:00	00:35:00	
8	CHP	Cc-105 SCR-10	B/C not running	OLR acted.Reset done	01:20:00	01:30:00	
9	CHP	Cc-51	MPD tripped	Reset done(6 times)	01:30:00	05:40:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/02/2026

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
10	CHP	Cc-102 TT	Reported TT movement not taking place	Old joint opened.Temporary joint done and placement given bypassing TT chute sensor and then permanent joint done and TT chute sensor kept in line	22:40:00	23:45:00	
11	WT	OP-1	Reported not moving	Emergency stop acted.Released and tested okay	02:00:00	02:10:00	
12	WT	OT-4	Reported tripped	D-2 tripped on PGEF-4 fault.Reset done	04:40:00	04:45:00	