



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 12/08/2025

Area: WT

Equipment	Job
EOT Crane(O)	Rubber pieces replaced to all three current collector pads
OT 3	Hopper area, 2*400 W SV fitting installed and light fixtures re arranged
OT 1 and 2	Hopper area, 2 nos chokes replaced and 2*400 W SV fittings installed
OP 1,4,5 and 7	After rake maintenance done