



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 16/10/2025

Incharge(s): Lal Singh

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|--------------------------------------|-------------------------------|----------------------------------|----------------------------------|---------|
| 1 | OHP | BRC ON CO-32 | BC NOT RUNNING .. EM STOP WIRE CUT | RECTIFIED AND TESTED | 14:40:00 | 15:00:00 | |
| 2 | OHP | BRC ON CO-32 | LT NOT WORKING .. M6 TRIPPED | RESET DONE | 15:00:00 | 15:10:00 | |
| 3 | CHP | CC-32 R-1 | BC ZSS CAGE STUCK WITH COAL | MADE FREE | 15:04:00 | 15:20:00 | |
| 4 | CHP | CC-31 SCR-4 | LUFF DOWN NOT WORKING | DOWN LIMIT STUCK ... RELEASED | 16:10:00 | 16:30:00 | |
| 5 | CHP | CC-35 | TRIPPED ON OLR (TAIL PULLEY JAMMING) | RESET DONE | 19:12:00 | 19:55:00 | |
| 6 | CHP | CC-54 | TRIPPED ON OLR | RESET DONE | 14:58:00 15:50:00 16:00:00 | 15:05:00 15:55:00 16:05:00 | |
| 7 | CHP | CC-51A | TRIPPED ON OLR | RESET DONE | 20:32:00 | 20:40:00 | |