



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/12/2025

Incharge(s): Lal Singh,Lal Singh

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26 WOBR	SLEW DRIVE TRIPPED	RESET DONE	07:15:00	07:30:00	
2	OHP	CO 8A BRC	CT DRIVE TRIPPED	RESET DONE	10:15:00	10:30:00	
3	CHP	CC-34 SCR-1	LT M1 TRIPPED	RESET DONE	06:30:00	06:40:00	
4	CHP	CC-125	TRIPPED ON OLR	RESET DONE	08:30:00 09:05:00	08:35:00 09:10:00	
5	CHP	CC-31 SCR-4	LT NOT WORKING ... PCRF CABLE FALL ..GUIDE PROBLEM	GUIDE ADJUSTED BY MECH ... CABLE WINDING DONE	08:45:00	08:55:00	
6	CHP	CC-104 SCR-9	LUFF NOT WORKING ... MPCB TRIPPED	MADE ON	09:15:00	09:25:00	
7	CHP	CC-54	TRIPPED 6 TIMES	RESET DONE	07:53:00	12:35:00	
8	CHP	CC-51	MPD TRIPPED 4 TIMES	RESET DONE	10:14:00	12:48:00	
9	WT	CP-1	CAME IN NO POWER ZONE INHALL SHIDE	REV DONE WITH JUMPERS	13:30:00	13:45:00	