



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 13/06/2025

Shift: A

Incharge(s): Nagendra Midde

| Sl No | Area | Equipment                                 | Problem   | Action                      | From                 | To                   | Remarks |
|-------|------|---|---|-----------------------------|----------------------|----------------------|---------|
| 1     | OHP  | CO33M                                     | DRIVE CHANGED                                   | CHECKED AND GOVEN CLEARENCE | 06:00:00             | 09:00:00             |         |
| 2     | OHP  | Brc on co 30<br>lt                        | pcrd o/t acted                                  | released                    | 08:10:00             | 08:30:00             |         |
| 3     | OHP  | CO 84 PC<br>ACTING<br>REPORTED            | EMERGENCY IS ACTED                              | RELEASED                    | 11:30:00             | 11:40:00             |         |
| 4     | OHP  | CO 29                                     | OLR ACTED                                       | RESET                       | 08:40:00             | 08:50:00             |         |
| 5     | CHP  | CC 125                                    | OLR ACTED                                       | RESET                       | 11:00:00<br>13:45:00 | 11:10:00<br>13:50:00 |         |
| 6     | CHP  | SCR 10 ON<br>CC 105                       | NEW CAGE FIXED FOR RECLAIMING YARD<br>INTERLOCK | CHECKED AND GIVEN CLEARENCE | 10:30:00             | 11:00:00             |         |
| 7     | CHP  | CC 131                                    | OLR ACTED                                       | RESET                       | 08:20:00             | 08:30:00             |         |
| 8     | CHP  | CC 58                                     | OLR ACTED                                       | RESET                       | 13:20:00             | 13:40:00             |         |
| 9     | CHP  | RG1<br>ACTING<br>DUE TO<br>UNDER<br>SPEED | MODULE PROBLEM                                  | BYPASSED                    | 10:30:00             | 11:00:00             |         |
| 10    | CHP  | CC 51                                     | B/S ACTED                                       | RESET                       | 07:15:00             | 07:30:00             |         |
| 11    | IOSA | OLD WBR<br>NO DRIVE<br>RUNNING            | AUXILIARY SUPPLY IS IN OFF CONDITION            | MADE IT ON                  | 07:20:00             | 07:30:00             |         |