



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 16/11/2025

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CR 2A	permissive not coming,lubrication pump is in off	made on	18:55:00	19:05:00	
2	OHP	BRC on CO 32	CT not working,DMPR tripped in Phase loss fault ,dmpR B phase cable loose connection,upper bolt missing, bottom bolt got welded	DMPR replaced ,	15:50:00	16:35:00	
3	OHP	BRC on co 28	B/W 1 not running,DMPR display unit not connected properly	connected properly	17:40:00	18:00:00	
4	OHP	TBS on co 20	PCRD control ckt problem,pcrd not working in remote,C3 and c4 both are in pickup,	control ckt kept as per drawing,C3 coil connection given throuh NC of C4, checked LT in remote PCRD movement ok, now all ok	16:40:00	17:00:00	no delay,sta cking was going on at that time
5	OHP	CO 8	olr acted	reset	21:30:00	21:35:00	
6	CHP	CC 48	CS acted due to jamming	informed operation	15:25:00	15:35:00	
7	CHP	CC 45	olr acted	reset it done	19:45:00	20:15:00	
8	CHP	CC 33 SCR5	LT not working,drive tripped	reset	19:50:00	20:05:00	
9	CHP	CC 33 SCR5	LT not working,m2 mpcb tripped,and OT acted	OT released,MPCB made on	20:10:00	20:25:00	
10	CHP	CC 222	ZSS acted found drive pulley jamming,	informed operation	19:45:00	20:00:00	
11	CHP	CC 223	not healthy,drive tripped	reset	20:15:00	20:30:00	
12	CHP	CC 110	OLR acted	reset	18:15:00	18:20:00	
13	CHP	CC 51	mpd tripped 5 times	reset	15:00:00	21:01:00	
14	CHP	VF 3	drive tripped	reset	18:05:00	18:15:00	