



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 21/09/2025

Shift: C

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

| Sl No | Area | Equipment       | Problem  | Action                    | From     | To       | Remarks                  |
|-------|------|-----------------|--|---------------------------|----------|----------|--------------------------|
| 1     | OHP  | CO 20           | BRS acted, transmitter not adjusted properly nut bolt loosened | properly adjusted than ok | 00:25:00 | 00:33:00 | to be checked in G shift |
| 2     | OHP  | VS 1            | olr acted, MPCB tripped  | made it on                | 04:00:00 | 04:10:00 |                          |
| 3     | OHP  | CO 26           | olr acted  | reset                     | 01:30:00 | 01:40:00 |                          |
| 4     | CHP  | CO 9            | OLr acted due to overload on belt                              | reset                     | 04:40:00 | 04:45:00 |                          |
| 5     | CHP  | CC 29 FLAP GATE | mpcb tripped   | made it on                | 22:20:00 | 22:30:00 |                          |
| 6     | CHP  | CC 21 (B)       | olr acted  | reset                     | 22:30:00 | 22:35:00 |                          |
| 7     | CHP  | CC 112 SCR8     | BC mpr tripped   | reset                     | 01:21:00 | 01:33:00 |                          |
| 8     | CHP  | CC 36 SCR1      | BW OLR acted   | reset                     | 01:55:00 | 02:05:00 |                          |
| 9     | CHP  | CC 34 SCR 2     | slew not working, slew limit acted                             | limit released            | 03:25:00 | 03:40:00 |                          |
| 10    | CHP  | CC 108          | OLR acted  | reset it done             | 03:35:00 | 03:40:00 |                          |
| 11    | CHP  | CC 40           | OLR acted  | reset                     | 04:25:00 | 04:35:00 |                          |
| 12    | WT   | OT 3            | D1 tripped in encoder fault                                    | reset                     | 05:35:00 | 05:40:00 |                          |