



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 23/07/2025

Area: OHP

Equipment	Job
brc-1 on oc-28	festoon cable adjustment is done.
co-49,co-9a,11a,12a, 11a cbms hoists	ppm is done.
co-14a gallery,, 12a galley,	illumination is improved.
rbf-2a	field devices in feedback checking is done.
wobr-2 on co-26	7c*1.5 cable laying from panels to io rack , started,
co-5	motor and feeder ppm is done. made list of equipment bypassed on operation requirement.,