



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 23/10/2025

Shift: A

Incharge(s): Nagendra Midde

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-------------------------------------|--|--------------------------------------|----------|----------|---------------------|
| 1 | OHP | CO 67 | OLR ACTED | RESET | 09:55:00 | 10:05:00 | |
| 2 | OHP | CO 24 RED DUE TO NO SUPPLY FOR DMPR | CONTROL MCB TRIPPING DUE TO EARTH FAULT IN SPACE HEATER CORE | SPACE HEATER CORE REMOVED MADE IT ON | 07:20:00 | 07:40:00 | INFORMED TO G SHIFT |
| 3 | OHP | BEC ON CO 31 | B/C OLR ACTED | RESET | 10:10:00 | 10:20:00 | |
| 4 | OHP | CO 26 | OLR ACTED | RESET | 11:50:00 | 12:00:00 | |
| 5 | OHP | CO 85 | B/S BYPASS LOOP LOOSE CONNECTION | TIGHTENED THEN OK | 12:20:00 | 12:30:00 | |
| 6 | OHP | RSCO 10A | CARRIAGE DRIVE TRIPPED | MADE IT ON | 12:00:00 | 12:10:00 | |
| 7 | CHP | CC 51 | FEEDING CONV OLR ACTED | RESET | 09:30:00 | 09:35:00 | |
| 8 | CHP | CC 52 | FEEDING CONV CC 113 STOPPED | RESET | 08:00:00 | 13:45:00 | 8 TIMES |
| 9 | CHP | CC 54 | OLR ACTED | RESET | 07:30:00 | 10:30:00 | 7 TIMES |
| 10 | CHP | SCR 10 LT | M2 TRIPPED DUE TO TRACK JAM | MRESET AND INFORMED TO OPRN | 06:50:00 | 07:00:00 | |
| 11 | CHP | SCR 8 ON CC 112 | B/C ZSS ACTING DUE TO JAMMING | AFTER CLEAMNING OK | 07:00:00 | 07:15:00 | |
| 12 | CHP | SCR 6 ON CC 38 LT | M1 TRIPPED DUE TO TRACK JAMMING | RESET | 11:30:00 | 11:35:00 | |
| 13 | CHP | S3 ON CC 111 | TUL C/S ACTED PROBE CLEANED | THEN OK | 12:20:00 | 12:40:00 | |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/10/2025

Incharge(s): Nagendra Midde

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-------------------------------|--------------------------|--------------|----------|----------|---------------------|
| 14 | CHP | S3 ON CC 111 SLEW NOT WORKING | SLEW POWER KEPT OFF | MADE IT ON | 12:20:00 | 12:40:00 | |
| 15 | CHP | CC 111 | B/S ACTED | BYPASSED | 12:30:00 | 12:40:00 | INFORMED TO G SHIFT |
| 16 | CHP | R1 ON CC 32 | ZSS INTERLOCK CAGE STUCK | MADE IT FREE | 12:40:00 | 12:50:00 | |
| 17 | CHP | CC 28 | OLR ACTED | RESET | 12:30:00 | 12:35:00 | |