



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/05/2025

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29	OLR ACTED	RESET DONE	14:10:00 19:20:00	14:15:00 19:30:00	
2	OHP	CO-29	TRIPPED ON SPP	RESET DONE AND TESTED CURRENTS CHECKED FOUND OK	16:00:00	16:10:00	
3	OHP	RSCO-10A	TRIPPED ON OLR	RESET DONE	15:30:00	15:40:00	
4	OHP	co-34	TRIPPED ON OLR	RESET DONE	17:25:00	17:30:00	
5	OHP	VS-2A	CHUT SENSOR ACTING DUE TO STONES TUCHING	CHECKED CHUT SENSOR WORKING FINE	15:30:00	15:45:00	
6	CHP	ALL MACHINES	COMMUNICATION PROBLEM	CCR MODEM REBOOT DONE	21:20:00	21:40:00	
7	CHP	CC-27A	CHUT SENSOR MODULE GLASS RELAY LOOSE	FIXED PROPERLY	19:30:00	19:45:00	
8	CHP	CC-41	C/S SHOWING RED	CHUT SENSOR ALREADY IN SERIES WITH PB.... CHUT SENSOR BIT BYPASSED IN PROGRAM	17:45:00	18:10:00	
9	CHP	CC-54	TRIPPED ON OLR	RESET DONE	14:05:00 14:55:00	14:10:00 15:00:00	
10	CHP	CC-131	TRIPPED ON OLR	RESET DONE	19:55:00	20:00:00	
11	CHP	CC-113	MECH BRS SWITCH PROBLEM	REPLACED	15:00:00	15:20:00	
12	WT	OP-10	ES PB ACTED	RELEASED	14:00:00	14:20:00	