



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 04/07/2025

Area: OHP

Equipment	Job
co-6,co-9	vibration values are recorded, found ok.
co-5,6,7,1a	zss probes and cjd inspection is done.
co-17 and h/e hoist	motor and panel side ppm is done
brc-4 on co-34	new rtd for oil temperature in installed at tank, found fluctuating values while run brc in condition, to be checked further, informed instrumentation .
co-15a cjd	cjd checking is done.
old daybins compressor-1	mccb problem identified, to be replaced and testing needs o be done after mechanical clearance.
co-13a pullchord	kept in circuit.
sb-6 bunker airblaster	auto sequence operation is checked and found ok, mechanical side issues are present, informed concerned.
co-51	estop pb of carriage and belt drive changed and tested.
tbs on co-22	ht cable old joint flash over took place, jointed again by dnw, replaced fuses at io and charged tbs.
wobr-4 on co-6a	5.5kw lt spare motor placed on bed , to be coupled.