



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 20/07/2025

Area: OHP

Equipment	Job
Processor-C and OCR HMI's	EPROM loading and warm restart is done. OCR HMI's wincc was reset.