



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 09/12/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO-21	REPORTED LT NOT TAKING PLACE FOUND LT BRAKE PROBLEM	BRAKE ADJUSTED WITH MECHANICAL HELP THAN OK	07:40:00	08:00:00	
2	OHP	CO-45	OLR ACTED	RESET DONE	07:10:00	07:20:00	
3	OHP	TBS ON CO-5A	LT NOT TAKING PLACE M-2 OLR ACTED	RESET DONE	13:00:00	13:10:00	
4	OHP	WOBR ON CO-26	LT NOT TAKING PLACE PCRD O/T ACTED	RELEASED THAN OK	13:20:00	13:35:00	
5	CHP	CC-14	OLR ACTED	RESET DONE	09:45:00	09:50:00	
6	CHP	CC-51	MPD TRIP (FEEDING CONVEYOR STOP) (7 TIMES)	RESET DONE	08:20:00	10:25:00	
7	CHP	CC-113 S-3	REPORTED SIGNAL MISSING	S-3 PLACED MIDDLE AREA THAN OK	06:45:00	07:30:00	
8	CHP	CC-105 SCR-10	REPORTED SLEW NOT WORKING FOUND 30 DEGREE LIMIT ACTED	RELEASED THAN OK	07:45:00	08:00:00	
9	CHP	CC-38 SCR-6	LT NOT WORKING FOUND PCRD CABLE INSULATION STUCK IN GUIDE	REMOVED THAN OK	09:10:00	09:35:00	
10	CHP	CC-45	REPORTED STOPPING ON ZSS FOUND ZS PROBE DAMAGED	ZSS PROBE REPLACED WITH NEW ONE THAN OK	10:20:00	10:45:00	