



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/08/2025

Incharge(s): K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-111	OLR ACTED	RESET	22:50:00	23:00:00	
2	OHP	BRC ON CO-34	CT OVER TRAVEL TOWARDS OPERATOR CABIN SIDE DUE TO END STOPPER LIFTED SO END LIMIT NOT OPERATED	END STOPPER ADJUSTED THAN OK	23:45:00	00:00:00	
3	OHP	CR-1	OIL FLOW LEVEL LOW	FLOAT SWITCH ADJUSTED THAN OK	01:00:00	01:15:00	
4	OHP	RSCO-10A (C/D)	OLR ACTED	RESET	03:00:00	03:15:00	
5	OHP	CO-26	OLR ACTED	RESET	03:15:00	03:25:00	
6	OHP	CO-35	OLR ACTED	RESET	03:55:00	04:05:00	
7	OHP	RSCO-1A	STOPPING ON ZS CHECKED ZS PROBE DAMAGED	ZS PROBE REPLACED THAN OK	03:30:00	04:00:00	
8	OHP	RSCO-1A	STOPPING ON ZS CHECKED ZS CAGE STUCK UP	ZS CAGE REPLACED THAN OK	05:30:00	06:00:00	
9	OHP	WOBR ON CO-29	LT NOT TAKING PLACE DRIVE TRIP	DRIVE RESET	06:00:00	06:15:00	
10	OHP	BIPC-1	OLR ACTED	RESET	06:00:00	06:15:00	
11	CHP	CC-39 SCR-6	B/C AND BW NOT RUNNING CHECKED JAMMING	INFORM TO OPERATION	00:40:00	01:10:00	
12	CHP	CC-104 SCR-9	SIGNAL PROBLEM	LT TAKEN REV DIRECTION THAN OK	04:00:00	04:10:00	
13	CHP	CC-35 SCR-1	SLEW AND LT NOT TAKING PLACE CHECKED NO PROBLEM FOUND	WRONG COMPLAINT	05:00:00	05:15:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/08/2025

Incharge(s): K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC-51	OLR ACTED	RESET	03:50:00	04:00:00	
15	CHP	CC-113	STOPPING ON ZS	JAMMING INFORM TO OPETATION	01:55:00	02:05:00	
16	CHP	CC-114	OLR ACTED	RESET	05:50:00	06:00:00	
17	WT	SCO-1A(C/D)	OLR ACTED	RESET	03:30:00	03:40:00	