



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 28/06/2025

Area: OHP

Equipment	Job
tt-2	chute vibrator is rectified and restored for operation.
co-11,12,13,rsc-10a	discharge chute vibrators status is checked
tbs-21	chute vibrator in installed and trail run taken.
tbs-24 removed transformer	oil is removed at hvmcc-1
brc-4 on co-34	running inspection is done.
wbr-29,25,26	bucket wheel motors inspection is done
tbs-4	shifted from co-5a to co-23
locp-1	for crusher-1 and 2 spare vc fixed in spare panel of crushers
co-45 spare motor	made ready , termination at tb done properly, trial run taken and shifted to co-45 level.