



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 14/01/2026

Incharge(s): K SANKARA RAO

Shift: A

| Sl No | Area | Equipment    | Problem   | Action                              | From                 | To                   | Remarks |
|-------|------|--------------|---|-------------------------------------|----------------------|----------------------|---------|
| 1     | OHP  | TBS ON CO-20 | REPORTED LT NOT TAKING PLACE FOUND PCRD O/T ACTED     | RELEASED AND PCRD GUIDE ADJUSTED    | 06:40:00             | 07:00:00             |         |
| 2     | CHP  | CC-28        | TRIPPED ON OLR (2TIMES)                               | RESET DONE                          | 10:50:00<br>12:20:00 | 11:00:00<br>12:30:00 |         |
| 3     | CHP  | CC-51        | OLR ACTED   | RESET DONE                          | 08:00:00             | 08:10:00             |         |
| 4     | CHP  | CC-51        | MPD TRIP (6TIMES) FEEDING CONVEYOR STOP               | RESET DONE                          | 07:00:00             | 13:30:00             |         |
| 5     | CHP  | CC-31        | MPD TRIP ( E108)                                      | RESET DONE                          | 07:30:00             | 07:35:00             |         |
| 6     | CHP  | CC-112 SCR-8 | REPORTED B/W NOT RUNNING CHECKED AND FOUND NO PROBLEM | POWER AND CONTROL RE-CYCLED THAN OK | 08:15:00             | 08:45:00             |         |
| 7     | CHP  | CC-216       | OLR ACTED   | RESET DONE                          | 08:40:00             | 08:50:00             |         |