



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 31/08/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: A

| Sl No | Area | Equipment     | Problem                               | Action   | From     | To       | Remarks |
|-------|------|---------------|---------------------------------------|--|----------|----------|---------|
| 1     | OHP  | CO 29         | OLR acted                             | reset done   | 06:20:00 | 06:30:00 |         |
| 2     | OHP  | BRC on CO 31  | LT not taking place due to M6 tripped | reset done   | 08:50:00 | 09:00:00 |         |
| 3     | OHP  | BRC on CO 28  | BC not running due to OLR acted       | reset done   | 08:45:00 | 08:55:00 |         |
| 4     | OHP  | CO 85         | OLR acted                             | reset done   | 11:15:00 | 11:26:00 |         |
| 5     | OHP  | WOBR on CO 25 | Luff not working due to oil level low | Inform to operation  | 12:30:00 | 12:50:00 |         |
| 6     | CHP  | CC 37 , S 1   | LT not working                        | Drive tripped , reset  | 10:11:00 | 10:30:00 |         |
| 7     | CHP  | CC 32 , SCR 5 | LT not working                        | Local emergency acted , released                                 | 11:45:00 | 12:00:00 |         |
| 8     | CHP  | CC 104, SCR 9 | BW not running due to oil temp high   | checked, found that oil cooler motor tripped . Made on , then ok | 13:20:00 | 13:40:00 |         |
| 9     | CHP  | CC 114        | Tripped on overload ( 3 times)        | reset done   | 10:00:00 | 13:25:00 |         |
| 10    | CHP  | VF 101        | tripped on overload                   | reset done   | 12:00:00 | 12:10:00 |         |
| 11    | CHP  | CC 54         | Tripped on overload ( 5 times)        | reset done   | 08:30:00 | 13:00:00 |         |
| 12    | CHP  | CC 51         | MPD Tripped ( many times)             | reset  | 08:30:00 | 13:25:00 |         |
| 13    | WT   | OT 4          | Hydraulic pump not starting           | Control mcb tripped in plc panel , made on                       | 06:45:00 | 07:00:00 |         |